



PIMPRI CHINCHWAD MUNICIPAL CORPORATION
PIMPRI-411018
HEALTH DEPARTMENT

Email-healthho@pcmcindia.gov.in
Phone No. 020- 67333333

Website-www.pcmcindia.gov.in
Ext.No. 1336

No.DZone/7/WS/394/2024

Date :- 11/11/2024

" Safe drinking water and sanitary condition certificate "

It is certified that an inspection team headed by **Health Department** of Pimpri Chinchwad Municipal Corporation, Pimpri, Pune-411018, from Assistant Commissioner, Health Department, Pimpri Chinchwad Municipal Corporation, Pimpri-411018, inspected **VIBGYOR RISE SCHOOL** run by **Global Education Foundation, Situated at Survey No.12, Hissa No.1 to 5, City S.No.594,595 & 597, Pimple Saudagar, Pune-411027** On 25/04/2024, checked the water test reports, submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building and the campus as per norms prescribed by the State government norms.

The above is valid for a period of 11 /11/2024 to 10/11/2025



(Signature)
Assistant Commissioner
Health Department
Pimpri Chinchwad Municipal
Corporation, Pimpri-411018

To,

VIBGYOR RISE SCHOOL run by **Global Education Foundation,**
Survey No.12, Hissa No.1 to 5,
City S.No.594,595 & 597,
Pimple Saudagar, Pune-411027



(Signature)
Admin Manager
Vibgyor Rise Pimple Saudagar

(Signature)
Principal
Vibgyor Rise Pimple Saudagar



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune - 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO - ws/lab/957/2025

Date - 27/02/2025

To

The Principal,

Vibgyor Rise School,

Pimple Saudagar.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Vibgyor Rise School, Pimple Saudagar on Date: 25/02/2025 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /936/2025 dated 27/02/2025 & ws /lab /950/2025 dated 27/02/2025 the water Sample is safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory.

Chief Chemist
Pimpri Chinchwad Municipal Corporation
Pimpri -18

Admin Manager
Vibgyor Rise Pimple Saudagar



Principal
Vibgyor Rise Pimple Saudagar



PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

No-WS/LAB/950/2025.


Date - 27 / 02 / 2025.

DATE OF EXAMINATION - 25 / 02 / 2025.

NAME - Vibgyor Rise School

ADDRESS - Pimple Saudagar.

SOURCE - PCMC Water.


SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample	Nil.	0/100ml	-	Potable.
2					 CHIEF CHEMIST Water Treatment Plant Pimpri Chinchwad Municipal Corp. Nigdi, Pune 44
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


Admin Manager
Vibgyor Rise Pimple Saudagar




Principal
Vibgyor Rise Pimple Saudagar

<div>PIMPRI CHINCHWAD MUNICIPAL CORPORATION (W/S) DIVISION</div> <div>REPORT OF CHEMICAL EXAMINATION OF WATER</div>					
NAME - Vibgyor Rise School,			No-WS/LAB/936 /2025.		
ADDRESS - Pimple Saudagar.			Date - 27 / 02 /2025		
SOURCE - PCMC Water			Date of Receipt - 25 / 02 /2025.		
			Date of Examination - 27 / 02 /2025		
Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	1.88 NTU		
2	pH	6.5 to 8.5	7.25		
3	Total Hardness (as CaCO ₃)	200 mg/lit	56 mg/lit		
4	Chloride	250 mg/lit	10 mg/lit		
5	Calcium	75 mg/lit	9.61 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST
WATER TREATMENT PLANT, NIGDI, PCMC


Admin Manager
Vibgyor Rise Pimple Saudagar




Principal
Vibgyor Rise Pimple Saudagar