



BRUHAT BENGALURU MAHANAGARA PALIKE

Office Of The Medical Officer OF Health Mahadevapura Zone, Bangalore - 48

APPENDIX -XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

NO: BBMP/MOH/MDP/PR/ 06 /2024-25

DATE:08-04-2024

It is certified that an inspection team headed by Dr.Rakesh N Medical Officer of Health and Mahesh Kumar.S Sr.H.I. (Name Of Officers with designation) from BBMP Health Department (Name of Department/Office) Inspected the **VIBGYOR ROOTS AND RISE**, SY.No.84/3, Next to Vaswani Reserve, Panathur Main Road, Panathur Post, Bangalore East Taluk, Bangalore-560103 (Name & Address of the School) on 08-04-2024 (Date of Inspection) and found that the **VIBGYOR ROOTS AND RISE** (Name of School) has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T.Govt.

The Above NOC is Valid for the Period of Up to 31-03-2025

Signature with Seal :

Name

: Dr.Rakesh N

Designation

ಆರೋಗ್ಯ ವರದಿಗಾರರು
: Medical Officer of Health
ಬಿಬಿಎಂಪಿ ಮಹಾದೇವಪುರ ವಲಯ
ಬೆಂಗಳೂರು

To,

VIBGYOR ROOTS AND RISE

SY.No.84/3,

Next to Vaswani Reserve,

Panathur Main Road,

Panathur Post, Bangalore East Taluk,

Bangalore-560103

For VIBGYOR ROOTS & RISE

Imresh
Principal

For VIBGYOR ROOTS & RISE

S. R.
Manager

GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/185/2024-85

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Dated: 18/04/2024

Report of Bacteriological analysis of Water/Effluent sample

Sample No.	Source & Particulars of Water Sample	Opinion				
		M.P.N Count	Plate Count	D.C Test	S.P.P	N.S.P.P & FC.
488	Router	Nil	-	-	SPP	-

Note:
M.P.N Count:
 Most probable number of Bacteria per 100ml of Water
D.C Test:
 Differential Coliform test
Plate Count:
 Plate Count per ml of sample
SPP:
 Water is satisfactory for Potable purpose
NSPP:
 Water is not satisfactory for Drinking purpose
NSPP & FC:
 Water is not satisfactory for Drinking purpose and E.Coli found

For VIBGYOR ROOTS & RISE

Smriti
Principal

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru

S. K.
Manager
(PTO)

For VIBGYOR ROOTS & RISE

Advice:

1. Sample.....
Need effective chlorination before use
2. Sample.....
Need to avoid possible source of faecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coli count per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

For VIBGYOR ROOTS & RISE

Srinivas
Principal

For VIBGYOR ROOTS & RISE

S. A.
Manager